



Postal Address:
 PO Box 4282
 Dandenong South, Victoria 3164
 Australia

Report Sponsor	Issue Date	Expiry Date
Ventech, 32 Thornycroft Street, Campbellfield VIC 3061	17/12/12	31/12/17

Introduction

This is an assessment of the fire hazard properties of “Ventech Black Cinder MDF, an FR treated MDF with a Eucalypt (*Eucalyptus globulus*) veneer coated in a water borne coating, as stated by the test sponsor” in accordance with AS/NZS 3837:1998 - *Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter* and Specification A2.4 of the Building Code of Australia.

For the verification of fire hazard properties the National Construction Code of Australia 2012 (NCC) Specification C1.10 requires testing to AS ISO 9705 “Fire tests – Full scale room test for surface products” or AS/NZS 3837:1998 “Method of test for heat and smoke release rates for material and products using an oxygen consumption calorimeter”. ISO 9705 is commonly referred to as the “ISO room fire test”, whilst AS/NZS 3837 is better known as the “Cone calorimeter test”.

As an alternative to an ISO 9705 test the NCC permits testing to AS/NZS 3837:1998 “Method of test for heat and smoke release rates for material and products using an oxygen consumption calorimeter” in conjunction with the prediction method outlined in Specification A2.4 of the NCC.

The main outcome from these tests is a material’s “group number”. The materials group number is an indication of its ‘time to flashover’ in the ISO room fire test. The group number may be gained directly from testing a material in the above mentioned ISO room fire test, or alternatively be predicted using data obtained from testing of the material in the cone calorimeter.

Referenced Test Report	Reference Date	Test Standard	Test Sponsor
EWFA 2790600a.1	17/12/2012	AS/NZS 3837-1998	Ventech

Description of Assessed Specimen

The three specimens tested in the referenced report were 98.9mm by 98.9mm by 13.0mm thick samples of a FR treated MDF with a Eucalypt (*Eucalyptus globulus*) veneer coated in a water borne coating, as stated by the test sponsor. The samples had a nominal mass per unit area of 10.46 kg/m³. The test specimens were supplied fully prepared for testing by the test sponsor and EWA personnel were not involved with either the selection or preparation of these test specimens. Prior to testing, the specimens were conditioned in accordance with BSEN 13238-2001 at a temperature of 23 +/- 2 deg C and relative humidity of 50 +/- 5% for a continuous period of more than 48 hours.

TESTING AUTHORITY	Exova Warringtonfire Aus Pty Ltd	
Address	PO Box 4282 DANDENONG SOUTH VIC 3164 Unit 2, 409-411 Hammond Road DANDENONG VIC 3175	
Phone / Fax	61 (0)3 9767 1066 / 61 (0)3 9767 1001	
ABN	81 050 241 524	
Email / Home Page	www.exova.com	
Authorisation	Prepared By: J. Richardson	Reviewed By: P. F. Motteram

Relevance of Results

Surface Characteristics

The exposed specimen surfaces were flat with uniformly distributed irregularity and it is confirmed that more than 50 % of the upper surface of the specimen was within 10mm of the plane taken across the highest points. No more than 30 % of the upper surface was comprised of cracks fissures or holes.

Asymmetric Products

It is confirmed that the specimen was Asymmetric in its construction and was tested with its faced surface exposed to the irradiance.

Thin Products

Products that are very thin can burn very quickly and provide insufficient data for accurate analysis of results. Upon inspection of the results of the referenced test it is considered that enough data has been collected for accurate analysis.

Joints

The specimen did not incorporate joints.

Melting and Dripping of Specimen

Results from products prone to melting dripping and collapsing may not be suitable for detailed mathematical analysis. It is confirmed that the referenced test material was not prone to such behaviour.

Mounting Methods

As the specimen was thicker than 6mm it is appropriate to use the standard mounting method in AS/NZS3837-1998 as was done in this test.

Time Interval for Results

The time interval for results in the referenced test was 5 seconds or less.

Relevance to BCA Specification A2.4

Based on the above discussion it is confirmed that the test specimen met the requirements for test specimens of AS/NZS 3837-1998 and Specification A2.4 of the NCC. In addition the time interval for results collection met the requirements of Specification A2.4 of the NCC. Therefore it is considered that the referenced test data is suitable for calculation of the Group Number and the Average Specific Extinction Area in accordance with Specification A2.4 of National Construction Code of Australia.

Assessment Conclusion

Parameter	Specimen 1	Specimen 2	Specimen 3	Assessed Result
Group Number	1	1	1	1
Average Specific Extinction Area (m²/kg)	17.6	18.8	16.0	17.5m²/kg

Conditions / Applicability

This assessment report does not provide an endorsement by Exova Warringtonfire Aus Pty Ltd of the actual products supplied. The conclusions of this assessment may be used to directly assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions. The assessment can therefore relate only to the actual prototype test specimens, testing conditions, and methodology described in the supporting data, and does not imply any performance abilities of constructions of subsequent manufacture.

This assessment is based on information and experience available at the time of preparation. The published procedures for the conduct of tests and the assessment of test results are the subject of constant review and improvement and it is recommended that this report be reviewed on or, before, the stated expiry date. The assessment is valid provided no modifications are made to the systems detailed in this report. This report may only be reproduced in full without modifications by the report sponsor. Copies, extracts or abridgments of this report in any form shall not be published by other organisations or individuals without the permission of Exova Warringtonfire Aus.